



EVPÚ[®]

NOTIFIED BODY No. 1293

EC – CERTIFICATE OF CONFORMITY

No. 1293 – CPD – 0120
of February 4, 2009

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Optical smoke & heat detector SensoMAG M40

to connect on Control and indicating equipment, with which has declared compatibility and is powered from it

placed on the market by

TELETEK ELECTRONICS JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the factory

TELETEK ELECTRONICS JSC
14A Srebarna Str., 1407 Sofia, Bulgaria

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

EN 54-7: 2000/A1: 2002, EN 54-5: 2000/A1: 2002

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on February 4, 2009 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Ing. Karol Glamoš



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.

016808

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk


Appendix to EC Certificate of Conformity No. 1293 – CPD – 0120

The details and conditions of use for the **Optical smoke & heat detector SensoMAG M40**, placed on the market by **TELETEK ELECTRONICS JSC** and distributed by **TELETEK ELECTRONICS JSC** are:

To be used in accordance with the supplies installation instructions and in conjunction with the following base:

Base:

- B24** Standard base
- B24D** Standard base with Schottky diode



A handwritten signature in blue ink, appearing to be "Karol Glamoš".

Karol Glamoš

