



NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0543

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Conventional fire alarm detector SensoMAG S30

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

Teletek Electronics JSC 14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC 14A Srebarna Str., 1407 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-7:2000 EN 54-7:2000/A1:2002

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on April 11th, 2017 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

SO A NOWN OF BODY

Nová Dubnica, April 11th, 2017

053089

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk Page 1 / 2 FCO 425-13 Rev.1

Marek H u d á k

Annex to Certificate No. 1293 - CPR - 0543 from April 11th, 2017

Technical Specifications

The SensoMAG S30 is a detachable, resettable type of a conventional optical smoke detector. All the detector operational function, including the signals from optical chamber processing and its drift compensation, are controlled by a microcontroller. The detector operational conditions are indicated by two red LEDs under the translucent ribs on the detector head. Normal condition is indicated by short flashes of both LEDs with time period 8 s, Alarm condition is indicated by steady lit of both LEDs.

The detector is possible to connect to suitable conventional control panel by means of two-conductor shielded detection line and mounting base B24 or B24D. The detection line voltage shall be in the range of (12 to 30) V

DC, current threshold of alarm condition (10 to 15) mA.

Products parameters:

Operating voltage: 9 + 30VDC
Nominal operating voltage: 12/24VDC
Average current consumption quiescent state: < 50µA

Current consumption in alarm state

(with base type B24 and B24D): (with base type B24RD):

(with base type B12): Protected area: Instalation height:

Output in alarm state at terminal RI:

Degree of protection:

Operational temperature range:

Relative humidity:
Dimensions (incl. base):

Weight (incl. base):

- ООД/ С

20mA/12 + 30V 33mA/12V, 49mA/24V, 57mA/30V 18mA/9V, 29mA/12V, 32mA/15V up to 120m² (in accordance with EN 54) up to 16m (in accordance with EN 54)

20mA (max) / -3,3V

IP30

-10°C + 60°C (93 ± 3)% at +40°C

Ø102mm, h 42mm

160g

Essential characteritics	Test specification	Harmonised technical specifications	Performance
Nominal activation conditions / Sensitivity, response delay (response rime) and Performance under fire conditions	cl. 4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Operational reliability	cl. 4.2 to 4.5, 4.6=N/A, 4.7, 4.9 to 4.11	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Tolerance to supply voltage	cl. 5.5	EN 54-7:2000 EN 54-7:2000/A1:2002	
Durability of operational reliability and response delay: temperature resistance	cl. 5.8, 5.9	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Durability of operational reliability: vibration resistance	cl. 5.13 to 5.16	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Durability of operational reliability: humidity resistance	cl. 5.10, 5.11	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Durability of operational reliability: corrosion resistance	cl. 5.12	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass
Durability of operational reliability: electrical stability	cl. 5.17	EN 54-7:2000 EN 54-7:2000/A1:2002	Pass



Nová Dubnica, April 11th, 2017

Marek Hudák Director NB

EVPÛ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, <u>www.evpu.sk</u> Page 2 / 2 FCO 425-13 Rev.1